



*** NOTE:**

For reference in placing new curb stops and relocated curb boxes see L-9901.

**** NOTE:**

Should Poly tubing, Galvanized or Lead material be encountered the entire Service Line shall be replaced w/ Copper from the existing Corporation Stop to the new Curb Stop. Pipe Shall Be Copper Tubing Size (C.T.S.).

L-7102C.Dwg Revision Date: 1/2/13

CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER		STANDARD DETAIL WATER SERVICE RELOCATION	
APPROVED: <i>RC Westerfield</i> ADMINISTRATOR	5-16-13 DATE		